

Wheelchair Seat Cushion Testing Report

TEST INSTITUTION

Beneficial Designs, Inc.

Main Office
1617 Water Street, Suite B
Minden NV 89423
voice 775.783.8822
fax 775.783.8823

Testing Facility
290 Sunlit Lane
Santa Cruz CA 95060
voice 831.429.8447
fax 831.423.8450

TEST CUSHION

Manufacturer	<u>Action Products Inc.</u>	Width (cm)	<u>45.7 (18 in)</u>
Product Line Name	<u>Xact</u>	Length (cm)	<u>41.3(16.3 in)</u>
Model Name	<u>Lite</u>	Thickness (cm)	<u>8.1 (3.2 in)</u>
Manufacturer's Lot #	<u>Not Applicable</u>	Weight (gm)	<u>1,406</u>
Date of Manufacture	<u>December 2005</u>	Recommended maximum user weight (kg)	<u>113 (250 lb)</u>
Serial Number	<u>Not Applicable</u>		
HCPCS Seat Cushion Code	<u>K0652 Skin protection cushion, width <22 in</u>		

TESTING METHODOLOGY

Simulation testing was conducted according to the DMERC – Local Medical Review Policy – Final – Wheelchair Seating, Spring 2004¹.

CLI used 40 mm Date(s) of tests 15-16 January 2005

SUMMARY OF RESULTS

Prior to simulated use testing:

Loaded contour depth testPASSED
Overload test for measuring bottoming outPASSED

After simulated use testing:

Loaded contour depth testPASSED
Overload test for measuring bottoming outPASSED

Simulation tests demonstrated a loaded contour depth of at least 40 mm with an overload deflection of at least 5 mm.

Following testing simulating 18 months of use, simulation tests demonstrated a loaded contour depth of at least 40 mm with an overload deflection of at least 5 mm.

Minimum structural characteristics assessment for positioning cushions.....Not Applicable

Report prepared by:  17 January 2005
Allen Siekman, Testing Supervisor Date

POSITIONING CUSHION STRUCTURAL CHARACTERISTICS

The positioning cushion exhibited the following structural characteristic(s):

Not Applicable

* If the cushion is coded as K0654, K0655, K0656, and K0657 and has two or more structural characteristics or two or more air compartments, then the cushion is determined to have passed the structural characteristic assessment.

CUSHION LOADING INDENTERS

One cushion-loading indenter(s) (CLIs) was used to test the cushion:

- 1) Loaded Contour Jig (LCJ)

The LCJ met the specific design features of acceptable CLIs as specified in the SADMERC Wheelchair Cushion Testing Methodology². The results obtained with the LCJ are reported in the *Summary of Results* on page 1.

TEST RESULTS – PRIOR TO SIMULATED USE TESTING

Date of test	15 January 2005
Testing room conditions	Temperature (C) 21.7
	Relative Humidity (%) 48

Loaded Contour Depth with LCJ indenter	Test #1	Test #2	Test #3	Result
Lateral buttons of the CLI contacted the cushion when loaded to 140 N (31 lb)	Yes	Yes	Yes	Pass

Overload Test with LCJ indenter	Test #1	Test #2	Test #3	Result
1) Height of CLI when loaded to 140 N (31 lb) (standard load) (mm)	36.19	33.96	33.09	---
2) Height of CLI when loaded to 187 N (41 lb) (overload) (mm)	32.65	30.70	30.05	---
3) Height at standard load (#1) minus height at overload (#2) (mm)	3.54	3.26	3.04	---
4) Value in #3 rounded to the nearest 5 mm (mm)	5	5	5	---
5) Overload deflection* (mm) (median of the 3 values in #4)	---	---	---	5 Pass

* If the overload deflection is greater than or equal to 5 mm, then the cushion is determined not to have bottomed out during the test.

SIMULATED USE TESTING

To simulate cushion use, the test cushion was subjected to cyclic loading in a heated chamber. The test cushion was preconditioned for 30 minutes in a test chamber maintained at 70 ± 2 degrees C. The test cushion was then loaded to 500 ± 10 Newtons (112 ± 2 pounds) for 7,500 or 11,000 cycles (depending upon the type of cushion) at a rate of 30 times per minute using the RCLI in the test chamber maintained at 70 ± 2 degrees C.

The number of cycles was determined as follows:

For testing simulating 12 months of use:

40 pressure reliefs per day x 30 days per month x 12 months x RF \approx 7,500 cycles

For testing simulating 18 months of use:

40 pressure reliefs per day x 30 days per month x 18 months x RF \approx 11,000 cycles

where RF = 0.5, the reduction factor for testing at an elevated temperature.

This cushion was tested to 22,000 cycles.

Preconditioning of test cushion began at 1105 hrs

Test chamber temperature (deg C) 70

Date of test 15 January 2005

Time test started 1140 hrs

TEST RESULTS – AFTER SIMULATED USE TESTING

Date of test 16 January 2005

Testing room conditions Temperature (C) 22.2

Relative Humidity (%) 49

Loaded Contour Depth with LCJ indenter	Test #1	Test #2	Test #3	Result
Lateral buttons of the CLI contacted the cushion when loaded to 140 N (31 lb)	Yes	Yes	Yes	Pass

Overload Test with LCJ indenter	Test #1	Test #2	Test #3	Result
1) Height of CLI when loaded to 140 N (31 lb) (standard load) (mm)	33.30	32.19	31.97	---
2) Height of CLI when loaded to 187 N (41 lb) (overload) (mm)	30.29	29.42	28.95	---
3) Height at standard load (#1) minus height at overload (#2) (mm)	3.01	2.77	3.02	---
4) Value in #3 rounded to the nearest 5 mm (mm)	5	5	5	---
5) Overload deflection* (mm) (median of the 3 values in #4)	---	---	---	5 Pass

* If the overload deflection is greater than or equal to 5 mm, then the cushion is determined not to have bottomed out during the test.

COMMENTS

None

¹ DMERC – Local Medical Review Policy – Final – Wheelchair Seating, Spring 2004 (n.d.). Retrieved March 18, 2004, from Palmetto GBA Web site: http://www.palmettogba.com/palmetto/lmrps_dmerc.nsf/final/2A0A7017B7FBE65585256D1E0044C7BB?OpenDocument

² ISO/DIS 16840-2, Test methods for determining the physical and mechanical characteristics of devices intended to manage tissue integrity – Part 2 Seat cushions [working draft] (2003-10-30). Retrieved March 18, 2004, from the University of Pittsburgh Wheelchair Standards Information Web site: http://www.wheelchairstandards.pitt.edu/WCS_S/WCS_S_ISO/WCS_S_ISO_WG11/WCS_S_ISO_WG11_pdf/WCS_S_ISO_WG11_Stds_pdf/ISO_16840_2_DIS.pdf